



April 16, 2013

TO: PROSPECTIVE BIDDERS

**REMOVE AND REPLACE HVAC CHILLERS AT CITY HALL
AND THE POLICE DEPARTMENT, NO. P.W. 03-13-04**

CITY OF ALAMEDA

ADDENDUM NO. 1

Addendum No. 1 is hereby issued to make the following revision to the specifications. Additions are shown in **Bold Underline** and deletions are shown in ~~Strikeout~~.

- a. Section III. Scope of Work, Remedial Description, Page 20, and in Exhibit A Bidder's Proposal. The following paragraph is modified to read:

“Work Included:

City will furnish the chillers. Contractor to furnish ~~Furnish~~ all **other** specified units and—equipment shown in the project drawings and/or specified in the technical specification, Section Series 15600, 15050, 15080, and 15010 prior of dismantling/ disabling of current system.”

- b. Section III. Scope of Work, Remedial Description, Installation, Testing, Programming, Operating, Page 21, and in Exhibit A Bidder's Proposal. The following paragraph is modified to read:

Contractor will install City supplied chillers. Contractor shall provide and install all new pumps, ~~chillers,~~ piping components, water system balancing, control integration, initial water treatment, purging air handlers and priming, insulation and comply with all Specifications within Sections 15010, 15080, 15050, 15600, project drawings and manufacturer recommendations, etc. as indicated on the drawings for a complete and operating system. Caulk and seal using Sikaflex-1a polyurethane elastomeric sealant/adhesive, or approved equal.

Addendum No. 1
Remove and Replace HVAC Chillers
at City Hall and the Police Department, No. P.W. 03-13-04

April 16, 2013
Page 2

APPROVED: Jesse Barajas
Jesse Barajas
Public Works Superintendent

4/16/2013
Date

Receipt is hereby acknowledged of Addendum No. 1, Remove and Replace HVAC Chillers at
City Hall and the Police Department, No. P.W. 03-13-04

Company Name / Contractor

Date: _____

By: _____

**NOTE: THIS COMPLETE ADDENDUM, SIGNED AND DATED MUST BE
RETURNED WITH YOUR BID.**

G:\pubworks\padmin\MAINT\2013\Chiller Replacement\Add 1.doc